Approval Number 250655022 Test Report: 2412/1 & 2412/2



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

26th June 2025

Fox Fittings Sp. z.o.o. Wiezniow Oswiecimia 50, 43-330 Wilamowice, Poland

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYETHYLENE- COMPONENTS.

5240

Page 1of 8

'Fox Spigot and Electrofusion Fittings'. Black coloured, injection moulded polyethylene spigot and electrofusion fittings. For use with water up to 65°C.

APPROVAL NUMBER: 250655022

APPROVAL HOLDER: FOX FITTINGS SP. Z.O.O.

The Scheme reserves the right to review approval.

Approval 250655022 is valid between June 2025 and June 2030

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

Ian Hughes

WRAS Approvals Manager